

- 1. VALVE COVER SHALL BE ROUND AND MARKED WATER, SEWER OR RECLAIMED.
- 2. VALVES SHALL NOT BE LOCATED IN STREET CURBS.
- 3. VALVE COVERS SHALL BE PAINTED BLUE FOR WATER, GREEN FOR SEWER AND PURPLE FOR RECLAIMED.
- 4. LOCATOR WIRE ACCESS 2" SCHEDULE 80 PVC, FEMALE ADAPTER COUPLING AND 2" BRASS PLUG WITH RECESSED NUT. TERMINATE INSULATED, SOLID 10 GAUGE COPPER LOCATOR WIRES AT TOP WITH 12" OF EXTRA WIRE. INSULATED WIRE SHALL BE COLOR CODED (SEE NOTE #4).